
# **RECUVO B**

#### ZG Lighting Australia Pty Ltd

2/7 Millner Ave. Horsley Park, NSW 2175, AUS



www.thornlighting.com.au



IP44

## **Specifications**

This luminaire is designed to comply with the requirements of AS/NZS 60598

Supply Voltage: 220 - 240VAC ~ 50/60 Hz

Classification for Protection: Class 1 Earthed Metalwork - against electric shock

#### Rating:

1. IP44

2. IK08

## Warning



Installation must be carried out by a qualified electrician in accordance with local wiring regulations.

Any modifications to the luminaire must be carried out exclusively by a qualified electrician and in accordance with applicable provisions and regulations.

#### Cation: Risk of Electrical Shock



Ensure that the rated voltage and frequency of the luminaire are compatible with the electrical supply. Disconnect the mains power supply before installing, servicing or maintaining the luminaire.

Hot plug-in is not an option! The luminaire must be disconnected from the mains when being worked on, or risk damage to the LED.

The manufacturer shall not be liable for any damage resulting from inappropriate modifications to the luminaire or faulty installation!

## Non User-Replaceable Light Source:



The light source contained in this luminaire shall only be replaced by the manufacturer, his service agent or a similarly qualified personnel.

### **Changes to Specifications:**

The right is reserved to change the design and/or specifications without prior notice or public announcement

